




Main Power Supply System of SuperKEKB

Shu Nakamura

KEK

2018/9/25 6th POCPA Workshop



Interaction point;
Belle II detector

High Energy
Ring(HER); e^-

Low Energy
Ring(LER); e^+

e^+ Source

e^- Source

e^+ Damping
ring (DR)

Machine Parameters

2017/September/1	LER	HER	unit	
E	4.000	7.007	GeV	
I	3.6	2.6	A	
Number of bunches	2,500			
Bunch Current	1.44	1.04	mA	
Circumference	3,016.315		m	
ϵ_x/ϵ_y	3.2(1.9)/8.64(2.8)	4.6(4.4)/12.9(1.5)	nm/pm	():zero current
Coupling	0.27	0.28		includes beam-beam
β_x^*/β_y^*	32/0.27	25/0.30	mm	
Crossing angle	83		mrad	
α_p	3.20×10^{-4}	4.55×10^{-4}		
σ_δ	$7.92(7.53) \times 10^{-4}$	$6.37(6.30) \times 10^{-4}$		
V_c	9.4	15.0	MV	
σ_z	6(4.7)	5(4.9)	mm	
ν_s	-0.0245	-0.0280		
ν_x/ν_y	44.53/46.57	45.53/43.57		
U_0	1.76	2.43	MeV	
$\tau_{x,y}/\tau_s$	45.7/22.8	58.0/29.0	msec	
ξ_x/ξ_y	0.0028/0.0881	0.0012/0.0807		
Luminosity	8×10^{35}		$\text{cm}^{-2}\text{s}^{-1}$	

Beam current is
Two times larger than KEKB


×

Beam size at collision point is
20 times smaller than KEKB



Luminosity is
40 times higher than KEKB.

SuperKEKB master schedule



List of Magnet power supplies

- Newly fabricated or old power supplies for Main Ring

Output power	Newly fabricated PS	Reused PS (#overhauled)	
0.95 MW	2	0	Main dipoles
0.4-1 MW	9	0	Wigglers
0.1-0.5 MW	0	18 [#]	Main quadrupoles
2-105 kW	92	335 [#]	Bend./Quad./Sext.
0.3-2.4 kW	209+29	1493+ α	Steering magnets/ corrector coils
Total	312+29	1846+α	2158+α

- Newly fabricated power supplies for
final-focus superconducting magnets system(QCS)

2kA, 15V	8	0	QCS Main quads.
<500 A, 20 V	3	0	QCS Solenoids
$\pm 70A, \pm 10V$	43+2	0	QCS correction coils

Large class PS (Main Dipoles, Wigglers)




	Rated current (A)	Max. Voltage (V)
Main Dipoles	860, 840	1100
Wigglers	800 ~ 1400	350 ~ 750

Large class PS (Main Dipoles, Wigglers)

Output current stability

These are measured with high precision DCCTs, which are separated from control circuit of the PSs.



Medium class PS (Bend./Quad./Sext.)




	Rated current (A)	Max. Voltage (V)	Stability (Idiff/Irated)
Bend./Quad./Sext.	200 ~ 1250	10 ~ 120	$< 2 \times 10^{-5} / \text{day}$

Small class PS (Steerings, auxiliary coils)



	Rated current (A)	Max. Voltage (V)	Stability (Idiff/Irated)
Steerings, etc.	$\pm 5, \pm 10$	$\pm 50 \sim \pm 100$	$< 1 \times 10^{-4} / \text{day}$

Typical operation cycle of the power supplies



Magnetic field standardization: the output current is increased to the rated current of each power supplies and then decreased to 0 A. After this cycle, which is repeated several times, the output current is set at the desired value determined by the machine optics. This cycle cancel out a relict magnetic field and assure us of repeatability of the magnetic field.

Scheduled maintenance: Scheduled maintenance runs every two weeks.

PS Control system

1. Remote control

Setting output current, ON/OFF control, and reading various status of PS PSICM mounted in each Power Supply.

(PSICM = Power Supply Interface Controller Module)

Connected to the IOC through ARCNET.

ARCNET = Attached Resource Computer NETwork

2. Current monitor

Digital Voltmeter(KEITHLEY 2002 or 2001) with scanner(KEITHLEY 7001).

Connected to the IOC through GPIB or Ethernet.

3. Interlock system to protect Magnets and Power supplies

Standalone PLC system.


The IOC is embedded in the PLC module(F3RP61).

They are controlled with EPICS

(Experimental Physics and Industrial Control System).


KEKBlog system are logging channels of the EPICS records.

Remote control (ARCNET)



PSICM

(Power Supply Interface Controller Module)




a few ~ 10 PSs in series

SuperKEKB succeed KEKB

Some devices running in KEKB were replaced new ones.

New components for SuperKEKB are added on legacies from KEKB.



Some troubles occurred on the connection.

Trouble summary

in Phase 1 (2016.2.8 ~ 2016.6.28) / in Phase 2 (2018.3.19 ~ 2018.7.17)

Magnet power supply system works well except for following failures.


Failures in Large class PS	# of event	comment
AC input over current	13 / 0	AC distortion (RF system crowbar or/and VAR system [#] works)
AC input Stop, CB Fault	6 / 0	Earthquake, Malfunctions.

Failures in Medium class PS	# of event	comment
Thermostat	7 / 14	Thermal control equipment trouble. Poor air conditioning.
Over current (IGBT modules)	6 / 1	Modules were replaced. Repaired.
Cable GND fault	1 / 0	The fault cable was disconnected.
Tracking error	1	Fault in the polarity inversion circuit. Repaired.

Failures in small class PS	# of event	comment
DC-DC board failure etc.	10 / 2	Power supplies themselves were replaced.

^{#)} Compensation system for a reactive power in the AC power distribution facility. AC line phase-advancing capacitor equipment was automatically controlled. However, unexpected operation occurred in early stage of Phase 1. Since capacitors has been manually operated, failures doesn't occur.


AC input failure



Insert additional AC inductors(ACL).
Then the peak height of the inrush current is reduced.
Main dipole magnet PSs are treated with the ACL.
The others are postponed due to a budget.

Signal noise from switching PSs

Synchronization trigger status



- Ready
- Running
- N/A

Synchronization trigger :

When optics parameters are changed, all PSs have to drive synchronously to avoid beam loss.


Trigger input signal



P-Body (**50V**/div)
 N-Body (**50V**/div)
 P-N (5V/div)
 100µs/div



Filters : normal 0.1µF, common 0.1µF





P-Body (**5V**/div)
 N-Body (**5V**/div)
 P-N (5V/div)
 100µs/div

Summary


- SuperKEKB is an e^-e^+ collider, which succeeded KEKB.
- Operation of the SuperKEKB have started from 2015, and Phase2 have finished now.
- Some of the large class PSs and ~100 number of the medium class PSs are newly fabricated.
- The most number of the PSs (mainly small class PSs) are running with/without overhauls.
- Some troubles have occurred between the legacies of KEKB and the new power supplies for SuperKEKB.

Start up: system check and full power load test

Full-scale start-up tasks such as network test, interlock system test, full power load test, cable connection check to avoid abnormal heating, polarity check, magnet standardization test and so on were completed before February 8(2016) beam injection to the MR.



KEKBlog viewer




KEKBlog indicates 4W(who, when, what, where).
We have to investigate remains(why, how).


bit	Interlock
0	Output OC
1	Output OV
2	Thyristor Fuse
3	Case Temperature
4	Semicon. Failure
5	GND Fault
6	Emergency
7	External
8	DCCT Fault
9	-
10	Water Flow
11	-
12	-
13	Thermostat
14	Tracking
15	Fan


Archived data


Time	record name	value
06/10/2016 00:00:36.48	MGLPS:ZVQD1P_1:IMON	1.843338e-02
06/10/2016 00:00:49.85	MGLPS:ZVQD1P_1:IMON	1.876372e-02
06/10/2016 00:01:26.15	MGLPS:ZVQD1P_1:IMON	1.875872e-02
06/10/2016 00:01:39.35	MGLPS:ZVQD1P_1:IMON	1.843839e-02
06/10/2016 00:01:55.85	MGLPS:ZVQD1P_1:IMON	1.843338e-02
06/10/2016 00:02:18.95	MGLPS:ZVQD1P_1:IMON	1.844840e-02
06/10/2016 00:02:45.35	MGLPS:ZVQD1P_1:IMON	1.844339e-02
06/10/2016 00:03:11.75	MGLPS:ZVQD1P_1:IMON	1.843338e-02
06/10/2016 00:03:38.15	MGLPS:ZVQD1P_1:IMON	1.843839e-02
06/10/2016 00:04:04.55	MGLPS:ZVQD1P_1:IMON	1.844339e-02
06/10/2016 00:04:30.95	MGLPS:ZVQD1P_1:IMON	1.844840e-02
06/10/2016 00:04:44.15	MGLPS:ZVQD1P_1:IMON	1.844339e-02
06/10/2016 00:04:57.35	MGLPS:ZVQD1P_1:IMON	1.843839e-02
06/10/2016 00:05:10.55	MGLPS:ZVQD1P_1:IMON	1.843338e-02
06/10/2016 00:05:23.75	MGLPS:ZVQD1P_1:IMON	1.844840e-02
...		



Histogram of output current of steering magnet PSs







DB PT150KN161600V,150A
 C1~16.18mF,400VDC
 R4 F~4.4.3.3kΩ,100W
 D7 PD30KN161600V,30AX 2)

TR, TR1MS0-16SKP (絶縁値:50A,リセット自動)
 ZRS-165
 R1~35Ω

C-DB 0.033μF x 6

CH2:18mH
 C11 R41 C13 R43
 C12 R42 C14 R44
 D7
 C2
 C-ZVS:0.022μF x 4
 D1.02-PH200DVIAT201200V,200A)

コンデンサの取付バンドは選定品とする。***

HT1.5A17244
 D1~6-PH270F6600V,270A
 R41~6.22Ω,50W
 C41~64.700μF,1kV

本体内部温度監視用
 OHR12 90°C

CH4,5:0.7μH
 CH6,7:0.65μH
 C3:60μF,220μF,200VDC x 3P)
 C4:60μF,220μF,200VDC x 3P)
 R5:100Ω

Cpe,Cme:1μF(0.1μF x 10P)
 Rpe,Rme:100Ω (ER505P)
 SA1~3:24V
 DP-PH4.00H800V,400A)
 CT1,2:MACC PLUS

電圧検出基板

CR-DIV1
 Ra,Rb:4.70kΩ
 Rc,Rd:4.7kΩ
 Ca,Cb:0.01μF
 Cc,Cd:0.1μF

CR-DIV2
 Ra,Rb:4.70kΩ / 4.3kΩ
 Rc,Rd:4.7kΩ
 Ca,Cb:0.01μF
 Cc,Cd:0.1μF

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

リアパネル
 CN3へ

制御ユニット
 (Z17113)

RYCU制御基板

Io.FB

Io.MON

CT1

CT2

D.C (AC)

Power

Fan

Case Temp.

Trans Temp.

SW Temp.

予備

Fan ON

AC ON

AC 電源 ON

V_{an}

地絡検出

V_{mon}

外部モニタ用